

**COMMENTS FOR
APPLICATION TO TILE OPEN DITCH**

**BEDDING, DEPTH OF COVER, AND BACKFILL SHOULD BE DONE ACCORDING TO THE
MANUFACTURER'S GUIDELINES.**

FINISH GRADE OF PIPE INVERT (INSIDE BOTTOM) SHALL BE APPROXIMATELY 2"
BELOW EXISTING HARD BOTTOM AFTER REMOVAL OF ACCUMULATED SILT.

PROVIDE SURFACE DRAINAGE AWAY FROM ROAD. MINIMUM SLOPE SHALL BE 1"
PER FOOT ON SEEDED TURF SHOULDERS TO CENTERLINE OF EXISTING DITCH TO
PRIVATE PROPERTY ACCORDING TO PROPERTY OWNER'S REQUIREMENT.

ACCEPTANCE OF THE FINAL INSTALLATION SUBJECT TO THE WRITTEN OR
VERBAL APPROVAL OF THE PAULDING COUNTY ENGINEER'S OFFICE.